



Water Quality parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.44				Y
2	7.47				Y
3	7.51				Y
4	7.45				Y
5	7.41				Y
6	7.51				Y
7	7.52				Y
8	7.55				Y
9	7.51				Y
10	7.46				Y
11	7.48				Y
12	7.36				Y
13	7.26				Y
14	7.28				Y
15	7.39				Y
16	7.47				Y
17	7.42				Y
18	7.39				Y
19	7.37				Y
20	7.38				Y
21	7.47				Y
22	7.49				Y
23	7.49				Y
24	7.49				Y
25	7.46				Y
26	7.44				Y
27	7.43				Y
28	7.42				Y
29	7.51				Y
30	7.40				Y
31	7.42				Y
(No = N = Excursions)Total N's					0

<< Have
minimums
been met
for this day?

ENTRY POINT

PWS ID: 4100157



System Name:

Entry Point:

Sample period:

A

May 2025

Month / Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

Minimum Water Quality Parameters as set by State

pH 7.2

Signature: [Signature]

Facility DRC Dean Harvey #6980

Date: 6/4/2025

Send to DHS within 10 days after end of sampling period

DHS - Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (503) 731-4381