



Water Quality parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.39				Y
2	7.35				Y
3	7.39				Y
4	7.48				Y
5	7.45				Y
6	7.47				Y
7	7.45				Y
8	7.4				Y
9	7.50				Y
10	7.37				Y
11	7.31				Y
12	7.37				Y
13	7.40				Y
14	7.42				Y
15	7.46				Y
16	7.39				Y
17	7.39				Y
18	7.38				Y
19	7.41				Y
20	7.39				Y
21	7.39				Y
22	7.34				Y
23	7.33				Y
24	7.32				Y
25	7.48				Y
26	7.54				Y
27	7.49				Y
28	7.46				Y
29	7.44				Y
30	7.35				Y
31					
(No = N = Excursions)Total N's					0

<< Have
minimums
been met
for this day?

ENTRY POINT	
PWS ID: 4100157	
	
System Name:	
Entry Point:	A
Sample period:	Jun 2025
Month / Year	

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

Minimum Water Quality Parameters as set by State pH 7.2

Signature: 
Facility DRC Dean Harvey #6980
Date: 7/7/2025

Send to DHS within 10 days after end of sampling period
DHS - Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (503) 731-4381