



Water Quality parameter Monitoring Form **Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Sili	Y/N
1	7.41				Y
2	7.37				Y
3	7.37				Y
4	7.51				Y
5	7.49				Y
6	7.54				Y
7	7.53				Y
8	7.44				Y
9	7.42				Y
10	7.43				Y
11	7.39				Y
12	7.39				Y
13	7.37				Y
14	7.39				Y
15	7.39				Y
16	7.38				Y
17	7.37				Y
18	7.39				Y
19	7.39				Y
20	7.37				Y
21	7.31				Y
22	7.39				Y
23	7.38				Y
24	7.37				Y
25	7.53				Y
26	7.51				Y
27	7.50				Y
28	7.50				Y
29	7.51				Y
30	7.49				Y
31					
(No = N = Excursions)Total N's					0

<< Have
 minimums
 been met
 for this day?

ENTRY POINT	
PWS ID: 4100157	
	
System Name:	
Entry Point:	A
Sample period:	Sep 2025
	Month / Year

Number of excursions* during this month: 4
 (Count the number of days when any WQP was less
 than the minimum required)

Total excursions during the previous 5 months: 4
 (Over 9 excursions in 6 months is a violation. Entry
 Point and Distribution excursions are cumulative)

Minimum Water Quality Parameters as set by State
pH 7.2

Signature: 
 Facility DRC Dean Harvey #6980

Date: 10/6/25

Send to DHS within 10 days after end of sampling period
 DHS - Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (503) 731-4381