



**Water Quality parameter Monitoring Form  
Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Sili	Y/N
1	7.38				Y
2	7.44				Y
3	7.51				Y
4	7.53				Y
5	7.54				Y
6	7.54				Y
7	7.55				Y
8	7.52				Y
9	7.42				Y
10	7.43				Y
11	7.50				Y
12	7.41				Y
13	7.46				Y
14	7.42				Y
15	7.46				Y
16	7.62				Y
17	7.55				Y
18	7.56				Y
19	7.51				Y
20	7.58				Y
21	7.87				Y
22	7.57				Y
23	7.57				Y
24	7.57				Y
25	7.51				Y
26	7.44				Y
27	7.37				Y
28	7.37				Y
29	7.37				Y
30	7.39				Y
31	7.35				Y
					(No = N = Excursions) <b>Total N's</b>

<< Have minimums been met for this day?

<b>ENTRY POINT</b>	
PWS ID: 4100157	
	
System Name:	_____
Entry Point:	A
Sample period:	Dec 2025
	Month / Year

**Number of excursions\* during this month:** 0  
*(Count the number of days when any WQP was less than the minimum required)*

**Total excursions during the previous 5 months:** 0  
*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative )*

<b>Minimum Water Quality Parameters as set by State</b>  pH <span style="border: 1px solid black; padding: 2px;">7.2</span>
---

Signature:   
 Facility DRC Dean Harvey #6980  
  
 Date: 1/6/2026