



**Water Quality parameter Monitoring Form  
Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Sili	Y/N
1	7.53				Y
2	7.52				Y
3	7.54				Y
4	7.54				Y
5	7.55				Y
6	7.44				Y
7	7.42				Y
8	7.42				Y
9	7.43				Y
10	7.28				Y
11	7.27				Y
12	7.48				Y
13	7.48				Y
14	7.48				Y
15	7.51				Y
16	7.52				Y
17	7.57				Y
18	7.54				Y
19	7.52				Y
20	7.41				Y
21	7.45				Y
22	7.51				Y
23	7.51				Y
24	7.52				Y
25	7.55				Y
26	7.55				Y
27	7.55				Y
28	7.51				Y
29					
30					
31					
(No = N = Excursions) Total N's					<b>0</b>


<< Have minimums been met for this day?

<b>ENTRY POINT</b>	
PWS ID: 4100157	
	
System Name:	
Entry Point:	A
Sample period:	Feb 2026
	Month / Year

**Number of excursions\* during this month:** 0  
*(Count the number of days when any WQP was less than the minimum required)*

**Total excursions during the previous 5 months:** 0  
*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative )*

<b>Minimum Water Quality Parameters as set by State</b>  pH <span style="border: 1px solid black; padding: 2px;">7.2</span>
---

Signature:   
 Facility DRC Dean Harvey #6980

Date: 03/03/26

Send to DHS within 10 days after end of sampling period

DHS - Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (503) 731-4381