



**Water Quality parameter Monitoring Form
Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Sili	Y/N
1	7.52				Y
2	7.55				Y
3	7.57				Y
4	7.57				Y
5	7.64				Y
6	7.59				Y
7	7.55				Y
8	7.56				Y
9	7.49				Y
10	7.47				Y
11	7.47				Y
12	7.54				Y
13	7.46				Y
14	7.45				Y
15	7.52				Y
16	7.55				Y
17	7.56				Y
18	7.56				Y
19	7.56				Y
20	7.58				Y
21	7.67				Y
22	7.65				Y
23	7.59				Y
24	7.58				Y
25	7.58				Y
26	7.59				Y
27	7.51				Y
28	7.51				Y
29	7.49				Y
30	7.50				Y
31	7.51				Y
(No = N = Excursions) Total N's					0

<< Have minimums been met for this day?

ENTRY POINT	
PWS ID: 4100157	
CANBY UTILITY	
System Name:	_____
Entry Point:	A
Sample period:	Mar 2026
	Month / Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

Minimum Water Quality Parameters as set by State pH 7.2

Signature: _____
 Facility DRC Dean Harvey #6980

Date: 4/6/2026