

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	6.90				n
2	6.79				n
3	6.78				n
4	6.28				n
5	6.21				n
6	7.24				y
7	8.70				y
8	8.02				y
9	9.02				y
10	8.73				y
11	9.00				y
12	6.90				n
13	6.94				n
14	7.36	150			y
15	7.14	160			y
16	7.12	170			y
17	6.97	160			n
18	6.96	140			n
19	6.87	175			n
20	6.81	150			n
21	6.96	150			n
22	7.02	150			n
23	6.90	140			n
24	6.95	160			n
25	6.71	140			n
26	6.83	160			n
27	6.83	150			n
28	6.86	160			n
29	6.81	140			n
30	9.24	240			y
31	--				y

(No = N = Excursion) **Total N's**

<<Have
minimums
been met for
this day?

ENTRY POINT

PWS ID: 41 00163

System Name: Canby Regency

Entry Point: Spring

Sample Period: November/2025
Month/Year

Number of excursions* during this month: 19
(Count the number of days when any WQP was
less than the minimum required)

Total excursions during the previous 5 months: 27
(Over 9 excursions in 6 months is a violation. Entry
Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality
Parameters as set by**

pH 7.2
Alk TBD (Alkalinity)
PO4 (Orthophosphate)
Other ()

Print Name: Phillip Merrill

Signature: Phillip Merrill

Date: 12-10-25

Send to DWP within 10 days after end of
sampling period