

Day	pH	Alk	Phos	Other	Y/N
1	6.51	90			n
2	6.28	90			n
3	8.47	160			y
4	10.01	180			y
5	6.47	110			n
6	6.26	90			n
7	6.20	80			n
8	6.22	80			n
9	6.22	90			n
10	6.11	90			n
11	6.10	80			n
12	6.26	60			n
13	6.20	80			n
14	6.26	90			n
15	6.26	70			n
16	6.24	100			n
17	Power off				
18	6.47	140			n
19	6.55	80			n
20	6.47	180			n
21	7.51	150			y
22	7.70	140			y
23	6.56	100			n
24	6.48	100			n
25	6.16	90			n
26	6.64	100			n
27	7.22	150			y
28	7.25	170			y
29	7.13	150			y
30	7.50	150			y
31	7.29	140			y
					y

(No = N = Excursion) **Total N's** 21

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

0	0	1	6	3
---	---	---	---	---

System Name: Canby Regency

Entry Point: Spring

Sample Period: Decenber/2025
Month/Year

Number of excursions* during this month: 21
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 19
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH

7.2

Alk

TBD

(Alkalinity)

PO4

--

(Orthophosphate)

Other

(_____)

Print Name: Phillip Merrill

Signature: *Phillip Merrill*

Date: 1-9-2026

Send to DWP within 10 days after end of sampling period

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>