

Day	pH	Alk	Phos	Other	Y/N
1	7.48	160			Y
2	7.14	150			N
3	7.05	150			N
4	7.28	170			Y
5	7.28	160			Y
6	7.28	150			Y
7	7.31	150			Y
8	7.15	150			N
9	7.11	170			N
10	7.16	170			N
11	7.19	160			N
12	7.13	160			N
13	7.10	150			N
14	7.11	140			N
15	7.06	150			N
16	7.35	170			Y
17	7.53	160			Y
18	7.22	150			Y
19	7.16	140			N
20	7.14	150			N
21	7.05	140			N
22	7.09	130			N
23	7.04	120			N
24	6.95	120			Y
25	6.92	120			N
26	6.91	120			N
27	7.08	130			N
28	7.19	130			N
29	7.28	140			Y
30	7.36	150			Y
31	7.21	130			Y
(No = N = Excursion) Total N's					19

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

1 0 0 6 3

System Name: Canby Regency

Entry Point: Spring

Sample Period: JANUARY 2024

Month/Year

Number of excursions* during this month: 19

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 19

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH

7.20

Alk

(Alkalinity)

PO4

(Orthophosphate)

Other

()

Print Name: Phillip Merrill

Signature: Phillip Merrill

Date: 2-10-2026

Send to DWP within 10 days after end of sampling period