

Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3	7.1	3.2			Y
4					
5					
6					
7					
8					
9					
10					
11					
12					
13					
14					
15					
16					
17	6.9	31			N
18					
19					
20					
21					
22					
23					
24					
25					
26					
27					
28					
29					
30	6.8	23			N
31					

<<Have minimums been met for this day?

County: Hood River Agency: HOOD RIVER COUNTY

**ENTRY POINT**

**EP-A**

**PWS ID 4100172**

**CASCADE LOCKS, CITY OF**



Sample period: 3 / 2022  
 Month/Year

Number of excursions during this month: 2

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality Parameter(s) as set by State:**

pH	7.0
Alk	31.0 (Alkalinity)

Print Name: Sheldon Price

Signature: Sheldon Price

Date & Phone#: 4-5-22 541 374 8484

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's **2**