

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	рН	Alk	Phos	Other	Y/N
1	8,0	60			
1 2 3 4 5 6 7	8.0 7.7 7.8 7.9 7.9 7.44 7.45 7.64 7.64 7.6 7.7	60 34 48 40 32 47 40 36 40 42			
3	7,8	48			
4	7,8	40			
5	709	32			
6	709	47			
7	7,34	40			
8	7,44	36			9
9	7,45	40			
10	7,64	42			
11	7.8	3/			
12	7.6	34			
13	7, 7	35			
14 15 16 17	7,6	40			
15	7,6	36			
16	8,6	36			
17	7.8	37			
18	7.8	39			
19	7.8	36			
20	7.8	33			
21	7,9	36			
22	7.8	32			
21222324	8,6 7,8 7,8 7,8 7,9 7,9 7,9	31 34 55 40 36 36 37 39 36 33 36 37 36 37			
	700	31			
25	7.8	38			tat.
26	7,9	34			
27	7,6	54			
28	7.7	35			
29	7.7	41			
30					
31					
(No = N	1 = Exc	cursion)Total	N's	Ø

< <have< th=""><th>County: Hood River Agency: HOOD RIVER COUNTY</th></have<>	County: Hood River Agency: HOOD RIVER COUNTY		
minimums been met for	ENTRY POINT		
this day?	EP-A		
	PWS ID 4100172		
C	ASCADE LOCKS, CITY OF		
Sample pe	riod: ७५-२३		

Number of excursions during this month: _Ø

Month/Year

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Minimum Water Quality Parameter(s) as set by State:						
pH Alk	7.0 31.0	Alkalinity)				

Print Name: Sheldon Price	
Signature: Mulclam rubon	
Date & Phone#: 3-2-23	
0 11 0110 1111	

Send to DWP within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (971) 673-0405 Website: http://healthoregon.org/dwp/