

| Day | pH  | Alk | Phos | Other | Y/N |
|-----|-----|-----|------|-------|-----|
| 1   | 9.2 | 35  |      |       |     |
| 2   | 9.1 | 40  |      |       |     |
| 3   | 9.3 | 40  |      |       |     |
| 4   | 9.3 | 32  |      |       |     |
| 5   | 9.4 | 44  |      |       |     |
| 6   | 9.4 | 36  |      |       |     |
| 7   | 9.3 | 38  |      |       |     |
| 8   | 9.4 | 46  |      |       |     |
| 9   | 9.3 | 37  |      |       |     |
| 10  | 9.3 | 39  |      |       |     |
| 11  | 9.2 | 36  |      |       |     |
| 12  | 9.4 | 43  |      |       |     |
| 13  | 9.5 | 36  |      |       |     |
| 14  | 9.4 | 36  |      |       |     |
| 15  | 9.4 | 39  |      |       |     |
| 16  | 9.4 | 34  |      |       |     |
| 17  | 9.3 | 38  |      |       |     |
| 18  | 9.4 | 39  |      |       |     |
| 19  | 9.4 | 37  |      |       |     |
| 20  | 9.5 | 32  |      |       |     |
| 21  | 9.1 | 31  |      |       |     |
| 22  | 9.3 | 37  |      |       |     |
| 23  | 9.4 | 33  |      |       |     |
| 24  | 9.5 | 38  |      |       |     |
| 25  | 9.5 | 33  |      |       |     |
| 26  | 9.5 | 40  |      |       |     |
| 27  | 9.5 | 36  |      |       |     |
| 28  | 9.5 | 36  |      |       |     |
| 29  | 9.4 | 36  |      |       |     |
| 30  | 9.4 | 36  |      |       |     |
| 31  |     |     |      |       |     |

<<Have minimums been met for this day?

County: Hood River Agency: HOOD RIVER COUNTY

**ENTRY POINT**

**EP-A**

**PWS ID 4100172**

**CASCADE LOCKS, CITY OF**

Sample period: 9 / 23  
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality Parameter(s) as set by State:**

|     |                   |
|-----|-------------------|
| pH  | 7.0               |
| Alk | 31.0 (Alkalinity) |

Print Name: Sheldon Price

Signature: Sheldon Price

Date & Phone#: 10/2/23 541-490-5610

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0