

Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Other	Y/N
1	9.4	38			
2	9.4	33			
3	9.5	38			
4	9.6	42			
5	9.5	38			
6	9.6	36			
7	9.7	41			
8	9.6	36			
9	9.6	43			
10	9.7	38			
11	9.7	38			
12	9.7	37			
13	9.7	42			
14	9.7	36			
15	9.8	37			
16	9.7	35			
17	9.7	38			
18	9.7	40			
19	9.6	36			
20	9.7	38			
21	9.7	36			
22	9.7	38			
23	9.7	41			
24	9.7	40			
25	9.7	37			
26	9.7	36			
27	9.7	39			
28	9.7	43			
29	9.7	42			
30	9.7	44			
31	9.7	36			

<<Have minimums been met for this day?

County: Hood River Agency: HOOD RIVER COUNTY

**ENTRY POINT**  
**EP-A**

**PWS ID 4100172**  
**CASCADE LOCKS, CITY OF**

Sample period: 10/23/  
 Month/Year

Number of excursions during this month: 0  
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality Parameter(s) as set by State:**

pH	7.0
Alk	31.0 (Alkalinity)

Print Name: Sheldon Price  
 Signature: Sheldon Price  
 Date & Phone#: 11/2/23 541-490-5610

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0