

Day	pH	Alk	Phos	Other	Y/N
1					
2	7.0	39			
3	7.1	42			
4	7.0	38			
5	7.1	41			
6	7.0	46			
7	7.2	48			
8	7.1	36			
9	7.0	46			
10	7.1	48			
11	7.0	49			
12	7.2	44			
13	7.2	43			
14	7.1	50			
15	7.1	48			
16	7.1	41			
17	7.2	43			
18	7.2	52			
19	7.1	35			
20	7.1	40			
21	7.1	45			
22	7.2	41			
23	7.2	49			
24	7.2	44			
25	7.1	46			
26	7.1	47			
27	7.1	43			
28	7.1	47			
29	7.2	47			
30	7.0	48			
31	7.1	47			

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 00172

System Name: CASCADE LOCKS CITY OF

Entry Point: EP-A

Sample Period: 12/23
Month/Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.0

Alk 31 (Alkalinity)

PO4 (Orthophosphate)

Other (_____)

Print Name: Sheldon Price

Signature: Sheldon Price

Date: 1/2/24

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0