

Day	pH	Alk	Phos	Other	Y/N
1	7.3	36			
2	7.5	40			
3	7.1	37			
4	7.2	38			
5	7.7	45			
6	7.2	45			
7	7.0	38			
8	7.1	48			
9	7.1	44			
10	7.4	44			
11	7.3	48			
12	7.1	40			
13	7.2	41			
14	7.3	48			
15	7.1	54			
16	7.6	47			
17	7.5	37			
18	7.2	47			
19	7.1	41			
20	7.2	38			
21	7.1	38			
22	7.5	40			
23	7.4	31			
24	7.1	44			
25	7.4	47			
26	7.3	47			
27	7.1	44			
28	7.1	39			
29	7.1	32			
30	7.1	37			
31					

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 00171

System Name: City of Cascade Locks

Entry Point: EP-A

Sample Period: JUNE 24
Month/Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.1

Alk 31.0 (Alkalinity)

PO4 (Orthophosphate)

Other (_____)

Print Name: Sheldon Price

Signature: Sheldon Price

Date: 7/1/24

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0