

Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Other	Y/N
1	7.0	38			
2	7.0	34			
3	7.1	41			
4	7.1	38			
5	7.0	42			
6	7.3	44			
7	7.0	37			
8	7.1	47			
9	7.0	34			
10	7.1	40			
11	7.1	48			
12	7.1	44			
13	7.2	46			
14	7.1	35			
15	7.1	40			
16	7.1	41			
17	7.2	45			
18	7.4	35			
19	7.1	44			
20	7.1	38			
21	7.2	37			
22	7.2	46			
23	7.2	34			
24	7.3	36			
25	7.4	4.2			
26	7.1	46			
27	7.3	41			
28	7.2	43			
29	7.2	43			
30	7.1	33			
31	7.0	38			

(No = N = Excursion) Total N's 0

<<Have minimums been met for this day?

County: Hood River Agency: HOOD RIVER COUNTY

**ENTRY POINT**

**EP-A**

**PWS ID 4100172**

**CASCADE LOCKS, CITY OF**

Sample period: Aug 2024  
 Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality Parameter(s) as set by State:**

pH 7.0  
 Alk 31.0 (Alkalinity)

Print Name: Sheldon Price

Signature: Sheldon Price

Date & Phone#: 9/3/24 541-490-5610

Send to DWP within 10 days after end of sampling period