

Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Other	Y/N
1	7.2	44			
2	7.3	47			
3	7.3	49			
4	7.4	54			
5	7.4	42			
6	7.4	43			
7	7.1	34			
8	7.1	47			
9	7.3	48			
10	7.4	45			
11	7.3	50			
12	7.3	48			
13	7.3	45			
14	7.2	41			
15	7.3	62			
16	7.3	51			
17	7.2	49			
18	7.2	46			
19	7.4	50			
20	7.4	53			
21	7.4	50			
22	7.3	45			
23	7.0	40			
24	7.2	53			
25	7.2	56			
26	7.2	48			
27	7.3	48			
28	7.4	47			
29	7.4	50			
30	7.4	42			
31	7.3	58			

<<Have minimums been met for this day?

County: Hood River Agency: HOOD RIVER COUNTY

**ENTRY POINT**

**EP-A**

**PWS ID 4100172**

**CASCADE LOCKS, CITY OF**

Sample period: Jun 25  
 Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality Parameter(s) as set by State:**

pH 

7.0
-----

Alk 

31.0
------

 (Alkalinity)

Print Name: Sheldon Price

Signature: Sheldon Price

Date & Phone#: 2-3-25 541-490-5610

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 

0
---