

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.3	45			
2	7.5	53			
3	7.5	51			
4	7.5	47			
5	7.5	46			
6	7.5	50			
7	7.5	48			
8	7.5	50			
9	7.4	48			
10	7.2	49			
11	7.8	49			
12	7.3	42			
13	7.3	44			
14	7.3	41			
15	7.1	43			
16	7.2	46			
17	7.3	44			
18	7.2	44			
19	7.3	44			
20	7.5	43			
21	7.4	44			
22	7.1	49			
23	7.1	38			
24	7.4	44			
25	7.8	50			
26	7.6	46			
27	7.7	49			
28	7.8	51			
29					
30					
31					

<<Have
minimums
been met for
this day?

County: Hood River Agency: HOOD RIVER COUNTY

ENTRY POINT

EP-A

PWS ID 4100172

CASCADE LOCKS, CITY OF

Sample period: Feb 2025
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative).
An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH 7.0

Alk 31.0 (Alkalinity)

Print Name: Sheldon Price

Signature: Sheldon Price

Date & Phone#: 3-3-25 / 541 378 9484

Send to DWP within 10 days after end of
sampling period

(No = N = Excursion) **Total N's** 0