

## Water Quality Parameter Monitoring Form

## Lead & Copper Rule Corrosion Control

Day	рН	Alk	Phos	Other	Y/N
1 2 3 4 5 6 7	7.6	40			
2	7.7	45			
3	7.3	44			
4	7.6	33			
5	7.3	37			
6	7.7 7.3 7.6 7.3 7.3 7.3 7.3	40 45 46 46 48 38 39 40 48			
	7,3	40			
8	7.3	48			
9	7.3	38			
10	7,2	39			
11	7,8	42			
12	7,4	4			
13	7,3	73			
11 12 13 14 15 16	7.5	46			
15	716	40			
16	715	45			
17	7.5	44			
18	714	44 35			
19	7.4	43			
20	1.0	43 301 40			
21	71	40			
20 21 22 23 24	7.3 7.5 7.5 7.5 7.4 7.4 7.4 7.2 7.5	4/			
23	7.5	45			
	7.4	46			
25	7.6	46			
26	75	45			
27	713	48			
28	7,3	48			
29	7.4	46			
30	7.5	41			
31	7.5	44			
(No = 1	N = Ex	cursior	)Tota	ıl N's	0

< <have< th=""><th colspan="3">County: Hood River Agency: HOOD RIVER COUNTY</th></have<>	County: Hood River Agency: HOOD RIVER COUNTY				
minimums been met for	ENTRY POINT				
this day?	EP-A				
PWS ID 4100172					
CASCADE LOCKS, CITY OF					
Sample period: Mar 2025					
Month/Year					

Number of excursions during this month:

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference
Minimum Water Quality Parameter(s) as set by State:
pH 7.0 Alk 31.0 (Alkalinity)
Print Name: Shellon Paia

Print Name: Sheldon Prio 2

Signature: Sheldon Prio 2

Date & Phone#: 4-2-25 / 54/3748484

Send to DWP within 10 days after end of sampling period