

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.9	37			
2	7.7	40			
3	7.9	38			
4	7.6	41			
5	7.5	48			
6	7.9	51			
7	7.5	39			
8	7.2	44			
9	7.0	38			
10	7.1	40			
11	7.3	50			
12	7.7	43			
13	7.6	46			
14	7.6	49			
15	8.1	52			
16	7.0	43			
17	7.1	45			
18	7.2	49			
19	7.5	45			
20	7.6	43			
21	7.7	44			
22	7.5	36			
23	7.9	50			
24	7.5	45			
25	7.5	49			
26	7.4	36			
27	7.1	43			
28	7.1	36			
29	7.7	48			
30	7.5	43			
31	7.7	40			

<<Have
minimums
been met for
this day?

County: Hood River Agency: HOOD RIVER COUNTY

ENTRY POINT

EP-A

PWS ID 4100172

CASCADE LOCKS, CITY OF

Sample period: 5/25
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative).
An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH

7.0

Alk

31.0

 (Alkalinity)

Print Name: Sheldon Price

Signature: Sheldon Price

Date & Phone#: 6-3-25-5414905610

Send to DWP within 10 days after end of
sampling period

(No = N = Excursion) Total N's 0

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>