

Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Other	Y/N
1	7.6	41			
2	7.3	43			
3	7.7	44			
4	7.5	47			
5	7.5	44			
6	7.9	39			
7	7.8	41			
8	7.4	42			
9	7.5	47			
10	7.7	46			
11	7.7	45			
12	7.8	52			
13	7.9	47			
14	7.7	51			
15	7.5	53			
16	7.7	46			
17	7.7	45			
18	7.8	46			
19	7.4	51			
20	8.1	47			
21	8.7	47			
22	7.0	44			
23	7.4	42			
24	7.2	44			
25	7.5	48			
26	8.1	51			
27	7.0	46			
28	7.1	32			
29	7.1	50			
30	7.2	42			
31					

<<Have  
minimums  
been met for  
this day?

County: Hood River Agency: HOOD RIVER COUNTY

**ENTRY POINT**

**EP-A**

**PWS ID 4100172**

**CASCADE LOCKS, CITY OF**

Sample period: June 25  
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative).  
An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality  
Parameter(s) as set by State:**

pH 

7.0
-----

  
Alk 

31.0
------

 (Alkalinity)

Print Name: Sheldahl Price

Signature: Sheldahl Price

Date & Phone#: 7/1/25/541 490 5610

Send to DWP within 10 days after end of  
sampling period

(No = N = Excursion) Total N's 0

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>