

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.3	39			
2	7.1	44			
3	7.8	55			
4	7.3	50			
5	7.3	42			
6	7.4	40			
7	7.4	46			
8	7.5	43			
9	7.8	57			
10	7.8	46			
11	7.8	47			
12	7.4	40			
13	7.6	48			
14	7.4	43			
15	7.3	50			
16	7.6	54			
17	7.3	43			
18	7.5	54			
19	8.0	51			
20	7.0	54			
21	7.3	46			
22	7.4	48			
23	7.2	54			
24	7.2	50			
25	7.2	48			
26	7.1	48			
27	7.2	52			
28	7.2	51			
29	7.1	50			
30	7.4	51			
31	7.4	48			

(No = N = Excursion) Total N's 0

<<Have
minimums
been met for
this day?

County: Hood River Agency: HOOD RIVER COUNTY

ENTRY POINT

EP-A

PWS ID 4100172

CASCADE LOCKS, CITY OF

Sample period: July 25
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative).
An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH 7.0
Alk 31.0 (Alkalinity)

Print Name: Sheldon Price

Signature: Sheldon Price

Date & Phone#: July 2025

Send to DWP within 10 days after end of
sampling period