

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.3	44			
2	7.3	48			
3	7.4	50			
4	7.2	56			
5	7.1	51			
6	7.2	45			
7	7.1	46			
8	7.0	44			
9	7.3	41			
10	7.2	56			
11	7.4	52			
12	7.6	53			
13	7.6	53			
14	7.2	51			
15	7.6	48			
16	7.4	50			
17	7.2	45			
18	7.3	50			
19	7.4	54			
20	7.3	62			
21	7.4	62			
22	7.1	58			
23	7.1	73			
24	7.1	71			
25	7.0	64			
26	7.4	56			
27	7.4	47			
28	7.3	50			
29	7.2	48			
30	7.2	50			
31	7.1	39			

<<Have
minimums
been met for
this day?

County: Hood River Agency: HOOD RIVER COUNTY

ENTRY POINT

EP-A

PWS ID 4100172

CASCADE LOCKS, CITY OF

Sample period: Aug 25
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative).
An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH 7.0
Alk 31.0 (Alkalinity)

Print Name: Sheldon Price
Signature: Sheldon Price
Date & Phone#: 9/4/25 541-490-5610

Send to DWP within 10 days after end of
sampling period

(No = N = Excursion) **Total N's** 0