

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.4	43			
2	7.4	56			
3	7.2	46			
4	7.2	50			
5	7.5	54			
6	7.0	46			
7	7.2	40			
8	7.3	51			
9	7.2	46			
10	7.1	46			
11	7.4	60			
12	7.0	43			
13	7.1	48			
14	7.2	46			
15	7.0	46			
16	7.0	51			
17	7.3	54			
18	7.2	43			
19	7.0	50			
20	7.8	63			
21	7.3	54			
22	7.1	47			
23	7.0	43			
24	7.0	53			
25	7.0	52			
26	7.1	63			
27	7.1	54			
28	7.0	48			
29	7.1	46			
30	7.2	54			
31					

<<Have
minimums
been met for
this day?

County: Hood River Agency: HOOD RIVER COUNTY

ENTRY POINT

EP-A

PWS ID 4100172

CASCADE LOCKS, CITY OF

Sample period: sep 25

Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative).
An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH 7.0

Alk 31.0 (Alkalinity)

Print Name: Sheldon Price

Signature: Sheldon Price

Date & Phone#: 9 30 25 541.490.5610

Send to DWP within 10 days after end of
sampling period

(No = N = Excursion) Total N's 0