

6.5

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.1	49			
2	7.0	46			
3	7.1	48			
4	7.1	48			
5	7.2	44			
6	7.2	46			
7	7.2	40			
8	7.6	49			
9	7.5	54			
10	7.2	48			
11	7.6	45			
12	7.1	41			
13	7.1	48			
14	7.1	44			
15	7.2	40			
16	7.1	42			
17	7.6	45			
18	7.0	43			
19	7.0	41			
20	7.1	49			
21	7.1	43			
22	7.2	44			
23	7.3	41			
24	7.4	44			
25	7.3	48			
26	7.3	40			
27	7.0	51			
28	7.1	42			
29	7.2	45			
30	7.2	42			
31	7.1	38			

<<Have
minimums
been met for
this day?

County: Hood River Agency: HOOD RIVER COUNTY

ENTRY POINT

EP-A

PWS ID 4100172

CASCADE LOCKS, CITY OF

Sample period:

Oct 25
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative).
An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH 7.0
Alk 31.0 (Alkalinity)

Print Name: Sheldon Price

Signature: Sheldon Price

Date & Phone#: 11-3-25 541-490-5610

Send to DWP within 10 days after end of
sampling period

(No = N = Excursion) Total N's 0