



Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.0	41			
2	7.0	66			
3	7.3	54			
4	7.4	56			
5	7.3	53			
6	7.3	56			
7	7.3	57			
8	7.4	54			
9	7.3	50			
10	7.5	48			
11	7.3	50			
12	7.1	51			
13	7.4	48			
14	7.3	40			
15	7.5	38			
16	7.6	40			
17	7.5	42			
18	7.5	57			
19	7.3	47			
20	7.3	48			
21	7.4	45			
22	7.0	56			
23	7.1	46			
24	7.4	51			
25	7.4	49			
26	7.2	48			
27	7.0	50			
28	7.3	54			
29	7.3	50			
30	7.4	59			
31					

(No = N = Excursion) **Total N's** 0

<<Have
minimums
been met for
this day?

County: Hood River Agency: HOOD RIVER COUNTY

ENTRY POINT

EP-A

PWS ID 4100172

CASCADE LOCKS, CITY OF

Sample period: NOV 2025
 Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH	7.0
Alk	31.0 (Alkalinity)

Print Name: Shelton Price

Signature: Shelton Price

Date & Phone#: _____

Send to DWP within 10 days after end of sampling period