

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.7	56			
2	7.4	54			
3	7.2	56			
4	7.2	53			
5	7.3	55			
6	7.3	54			
7	7.3	51			
8	7.6	22			
9	7.4	49			
10	7.2	50			
11	7.3	50			
12	7.3	47			
13	7.3	49			
14	8.5	58			
15	7.3	49			
16	7.4	57			
17	7.3	53			
18	7.1	64			
19	7.2	49			
20	7.5	50			
21	7.2	44			
22	7.4	45			
23	7.4	56			
24	7.4	54			
25	7.4	57			
26	7.2	51			
27	7.3	48			
28	7.4	45	51		
29	7.1	45			
30	7.3	57			
31	7.1	43			

<<Have
minimums
been met for
this day?

County: Hood River Agency: HOOD RIVER COUNTY

ENTRY POINT

EP-A

PWS ID 4100172

CASCADE LOCKS, CITY OF

Sample period: Dec 25
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative).
An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH

7.0

Alk

31.0

 (Alkalinity)

Print Name: Sheldon Price
Signature: Sheldon Price
Date & Phone#: 1-5-26 541 490 5610

Send to DWP within 10 days after end of
sampling period

(No = N = Excursion) Total N's

0
