

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.5	36			
2	7.4	38			
3	7.5	38			
4	7.8	34			
5	7.4	36			
6	7.4	31			
7	7.5	39			
8	7.6	40			
9	7.6	35			
10	7.6	45			
11	7.5	38			
12	7.6	38			
13	7.5	34			
14	7.5	40			
15	7.5	34			
16	7.6	34			
17	7.6	33			
18	7.4	35			
19	7.6	35			
20	7.5	31			
21	7.6	34			
22	7.6	36			
23	7.5	33			
24	7.6	35			
25	7.5	31			
26	7.6	34			
27	7.5	32			
28	7.5	33			
29	7.5	31			
30	7.6	31			
31					

<<Have minimums been met for this day?

County: Hood River Agency: HOOD RIVER COUNTY

ENTRY POINT

EP-A

PWS ID 4100172

CASCADE LOCKS, CITY OF

Sample period: 6/22
 Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

Minimum Water Quality Parameter(s) as set by State:

pH 7.0
 Alk 31.0 (Alkalinity)

Print Name: Sheldon Price
 Signature: Sheldon Price
 Date & Phone#: 7/1/22 541 440 5610

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0