

Day	pH	Alk	Phos	Other	Y/N
1	7.6				Y
2	7.6				Y
3	7.7				Y
4	7.7				Y
5	7.6				Y
6	7.6				Y
7	7.6				Y
8	7.6				Y
9	7.6				Y
10	7.6				Y
11	7.6				Y
12	7.6				Y
13	7.6				Y
14	7.6				Y
15	7.6				Y
16	7.6				Y
17	7.7				Y
18	7.7				Y
19	7.6				Y
20	7.7				Y
21	7.6				Y
22	7.6				Y
23	7.6				Y
24	7.6				Y
25	7.6				Y
26	7.6				Y
27	7.6				Y
28	7.6				Y
29	7.6				Y
30	7.6				Y
31					

<<Have minimums been met for this day?

County: Clackamas Agency: REGION 1

ENTRY POINT
EP-A

PWS ID 4100187

**CLACKAMAS RIVER WATER -
CLACKAMAS**

Sample period: September 2021
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH 7.5

Print Name: Tracy Triplett

Signature: *Tracy Triplett*

Date & Phone#: 10.06.2021 (503) 793-3685

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0