

Day	pH	Alk	Phos	Other	Y/N
1	7.6				Y
2	7.6				Y
3	7.6				Y
4	7.6				Y
5	7.6				Y
6	7.5				Y
7	7.9				Y
8	7.6				Y
9	7.5				Y
10	7.6				Y
11	7.6				Y
12	7.6				Y
13	7.6				Y
14	7.5				Y
15	7.7				Y
16	7.7				Y
17	7.7				Y
18	7.7				Y
19	7.7				Y
20	7.7				Y
21	7.7				Y
22	7.7				Y
23	7.7				Y
24	7.7				Y
25	7.7				Y
26	7.7				Y
27	7.6				Y
28	7.7				Y
29	7.6				Y
30	7.6				Y
31					

<<Have minimums been met for this day?

County: Clackamas Agency: REGION 1

**ENTRY POINT**  
**EP-A**

**PWS ID 4100187**

**CLACKAMAS RIVER WATER - CLACKAMAS**

Sample period: November 2021  
Month/Year

Number of excursions during this month: 0

*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.*

Reference

Minimum Water Quality Parameter(s) as set by State:

pH 7.5

Print Name: Tracy Triplett

Signature: *Tracy Triplett*

Date & Phone#: 12.09.2021 (503) 793-3685

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0