

| Day | pH  | Alk  | Phos | Other | Y/N |
|-----|-----|------|------|-------|-----|
| 1   | 7.7 |      |      |       | Y   |
| 2   | 7.6 | 32.0 |      |       | Y   |
| 3   | 7.7 |      |      |       | Y   |
| 4   | 7.6 |      |      |       | Y   |
| 5   | 7.6 |      |      |       | Y   |
| 6   | 7.6 |      |      |       | Y   |
| 7   | 7.6 |      |      |       | Y   |
| 8   | 7.6 | 28.7 |      |       | Y   |
| 9   | 7.6 | 28.5 |      |       | Y   |
| 10  | 7.6 |      |      |       | Y   |
| 11  | 7.6 |      |      |       | Y   |
| 12  | 7.7 | 30.9 |      |       | Y   |
| 13  | 7.7 |      |      |       | Y   |
| 14  | 7.6 |      |      |       | Y   |
| 15  | 7.6 |      |      |       | Y   |
| 16  | 7.6 | 29.6 |      |       | Y   |
| 17  | 7.6 |      |      |       | Y   |
| 18  | 7.6 |      |      |       | Y   |
| 19  | 7.6 | 28.8 |      |       | Y   |
| 20  | 7.6 | 29.0 |      |       | Y   |
| 21  | 7.6 |      |      |       | Y   |
| 22  | 7.6 | 29.5 |      |       | Y   |
| 23  | 7.6 |      |      |       | Y   |
| 24  | 7.6 |      |      |       | Y   |
| 25  | 7.6 |      |      |       | Y   |
| 26  | 7.6 |      |      |       | Y   |
| 27  | 7.6 | 29.6 |      |       | Y   |
| 28  | 7.6 |      |      |       | Y   |
| 29  | 7.6 |      |      |       | Y   |
| 30  | 7.6 |      |      |       | Y   |
| 31  |     |      |      |       |     |

<<Have minimums been met for this day?

County: Clackamas Agency: REGION 1

**ENTRY POINT**

**EP-A**

**PWS ID 4100187**

**CLACKAMAS RIVER WATER - CLACKAMAS**


**Sample period: September 2022**  
*Month/Year*

**Number of excursions during this month: 0**

*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.*

*Reference*

**Minimum Water Quality Parameter(s) as set by State:**

pH 7.5  
 Alk 16.5 (Alkalinity) 

**Print Name:** Tracy Triplett

**Signature:** 

**Date & Phone#:** 10-03-2022 (503) 793-3685

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) **Total N's** 0