

Day	pH	Alk	Phos	Other	Y/N
1	7.6				Y
2	7.6				Y
3	7.6	29.0			Y
4	7.5				Y
5	7.6				Y
6	7.7	30.5			Y
7	7.6	29.5			Y
8	7.6				Y
9	7.6				Y
10	7.6				Y
11	7.6	29.8			Y
12	7.6				Y
13	7.6				Y
14	7.6	29.5			Y
15	7.6				Y
16	7.6				Y
17	7.6				Y
18	7.6	29.7			Y
19	7.6	30.1			Y
20	7.6	29.8			Y
21	7.6	28.8			Y
22	7.6				Y
23	7.7				Y
24	7.6	30.7			Y
25	7.6				Y
26	7.6				Y
27	7.6	27.0			Y
28	7.6				Y
29	7.6	27.8			Y
30	7.6				Y
31	7.6	28.2			Y

<<Have minimums been met for this day?

County: Clackamas Agency: REGION 1

ENTRY POINT

EP-A

PWS ID 4100187

**CLACKAMAS RIVER WATER -
CLACKAMAS**

Sample period: October 2022
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH 7.5
 Alk 16.5 (Alkalinity)

Print Name: Tracy Triplett

Signature:

Date & Phone#: 11.04.2022 (503) 793-3685

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) **Total N's** 0