

Day	pH	Alk	Phos	Other	Y/N
1	7.7				Y
2	7.7				Y
3	7.7				Y
4	7.7				Y
5	7.7	18.6			Y
6	7.7				Y
7	7.7				Y
8	7.7				Y
9	7.6				Y
10	7.6				Y
11	7.6				Y
12	7.6	17.8			Y
13	7.6				Y
14	7.6				Y
15	7.6				Y
16	7.6				Y
17	7.6				Y
18	7.6	16.0			N
19	7.6	16.7			Y
20	7.6				Y
21	7.6				Y
22	7.6				Y
23	7.6				Y
24	7.6	18.2			Y
25	7.6				Y
26	7.6				Y
27	7.6				Y
28	7.6				Y
29	7.6				Y
30	7.7				Y
31	7.7	19.9			Y

<<Have minimums been met for this day?

County: Clackamas Agency: REGION 1

**ENTRY POINT**

**EP-A**

**PWS ID 4100187**

**CLACKAMAS RIVER WATER - CLACKAMAS**

**Sample period: May 2023**  
 Month/Year

**Number of excursions during this month: 1**

*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.*

Reference

**Minimum Water Quality Parameter(s) as set by State:**

pH 7.5  
 Alk 16.5 (Alkalinity)

**Print Name:** Tracy Triplett  
**Signature:** *Tracy Triplett*  
**Date & Phone#:** 06/07/2023 (503) 793-3685

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) **Total N's** 1