

| Day | pH | Alk | Phos | Other | Y/N |
|-----|-----|------|------|-------|-----|
| 1 | 7.6 | | | | Y |
| 2 | 7.6 | | | | Y |
| 3 | 7.6 | 27.2 | | | Y |
| 4 | 7.6 | | | | Y |
| 5 | 7.6 | | | | Y |
| 6 | 7.6 | | | | Y |
| 7 | 7.6 | | | | Y |
| 8 | 7.6 | | | | Y |
| 9 | 7.6 | | | | Y |
| 10 | 7.6 | 29.4 | | | Y |
| 11 | 7.6 | | | | Y |
| 12 | 7.6 | | | | Y |
| 13 | 7.6 | | | | Y |
| 14 | 7.6 | | | | Y |
| 15 | 7.6 | | | | Y |
| 16 | 7.6 | | | | Y |
| 17 | 7.6 | | | | Y |
| 18 | 7.6 | 29.3 | | | Y |
| 19 | 7.6 | | | | Y |
| 20 | 7.6 | | | | Y |
| 21 | 7.6 | | | | Y |
| 22 | 7.6 | | | | Y |
| 23 | 7.6 | | | | Y |
| 24 | 7.6 | 29.2 | | | Y |
| 25 | 7.6 | 28.3 | | | Y |
| 26 | 7.6 | | | | Y |
| 27 | 7.6 | | | | Y |
| 28 | 7.6 | | | | Y |
| 29 | 7.6 | | | | Y |
| 30 | 7.6 | | | | Y |
| 31 | 7.6 | 30.1 | | | Y |

<<Have minimums been met for this day?

County: Clackamas Agency: REGION 1

ENTRY POINT

EP-A

PWS ID 4100187

**CLACKAMAS RIVER WATER -
CLACKAMAS**

Sample period: July 2023
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH 7.5
 Alk 16.5 (Alkalinity)

Print Name: Tracy Triplett

Signature:

Date & Phone#: 08/03/2023 (503) 793-3685

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) **Total N's** 0