

Day	pH	Alk	Phos	Other	Y/N
1	7.6				Y
2	7.6	30.5			Y
3	7.6				Y
4	7.6				Y
5	7.6				Y
6	7.6				Y
7	7.6				Y
8	7.6				Y
9	7.6	30.1			Y
10	7.6				Y
11	7.6				Y
12	7.6				Y
13	7.6				Y
14	7.6				Y
15	7.6				Y
16	7.6				Y
17	7.6				Y
18	7.7	28.4			Y
19	7.6				Y
20	7.6				Y
21	7.6				Y
22	7.6				Y
23	7.6				Y
24	7.6				Y
25	7.7	28.0			Y
26	7.8				Y
27	7.6				Y
28	7.6				Y
29	7.6				Y
30	7.6	27.9			Y
31	7.6				Y

<<Have minimums been met for this day?

County: Clackamas Agency: REGION 1

**ENTRY POINT**  
**EP-A**  
**PWS ID 4100187**  
**CLACKAMAS RIVER WATER - CLACKAMAS**

**Sample period: October 2023**  
*Month/Year*

**Number of excursions during this month: 0**

*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.*

*Reference* \_\_\_\_\_

**Minimum Water Quality Parameter(s) as set by State:**

pH 7.5  
 Alk 16.5 *(Alkalinity)*

**Print Name:** Tracy Triplett

**Signature:**

**Date & Phone#:** 11/08/2023 (503) 722-9241

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) **Total N's** 0