

Day	pH	Alk	Phos	Other	Y/N
1	7.7				Y
2	7.7				Y
3	7.7				Y
4	7.7				Y
5	7.7				Y
6	7.7				Y
7	7.7				Y
8	7.7				Y
9	7.7				Y
10	7.7				Y
11	7.7				Y
12	7.7				Y
13	7.7	22.5			Y
14	7.7				Y
15	7.7				Y
16	7.7				Y
17	7.7				Y
18	7.7				Y
19	7.7				Y
20	7.7	27.5			Y
21	7.7				Y
22	7.7				Y
23	7.7				Y
24	7.7				Y
25	7.7				Y
26	7.7				Y
27	7.7				Y
28	7.7				Y
29	7.6	21.5			Y
30					
31					

<<Have minimums been met for this day?

County: Clackamas Agency: REGION 1

**ENTRY POINT**

**EP-A**

**PWS ID 4100187**

**CLACKAMAS RIVER WATER -  
CLACKAMAS**

**Sample period: February 2024**  
Month/Year

**Number of excursions during this month: 0**

*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.*

*Reference*

**Minimum Water Quality  
Parameter(s) as set by State:**

pH 7.5  
 Alk 16.5 (Alkalinity)

**Print Name:** Tracy Triplett

**Signature:** *Tracy Triplett*

**Date & Phone#:** 03/07/2024 (503) 793-3685

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) **Total N's** 0