

Day	pH	Alk	Phos	Other	Y/N
1	7.6				Y
2	7.5				Y
3	7.5				Y
4	7.5				Y
5	7.5				Y
6	7.6	21.4			Y
7	7.4				N
8	7.5				Y
9	7.6				Y
10	7.5				Y
11	7.6				Y
12	7.7				Y
13	7.6				Y
14	7.6				Y
15	7.6				Y
16	7.5				Y
17	7.6				Y
18	7.5	23.9			Y
19	7.5				Y
20	7.6				Y
21	7.6				Y
22	7.6				Y
23	7.5				Y
24	7.7				Y
25	7.7	27.8			Y
26	7.6				Y
27	7.6	28.0			Y
28	7.6				Y
29	7.6				Y
30	7.5				Y
31					

<<Have minimums been met for this day?

County: Clackamas Agency: REGION 1

**ENTRY POINT**

**EP-A**

**PWS ID 4100187**

**CLACKAMAS RIVER WATER - CLACKAMAS**

Sample period: June 2024  
 Month/Year

Number of excursions during this month: 1

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality Parameter(s) as set by State:**

pH 7.5  
 Alk 16.5 (Alkalinity)

Print Name: Tracy Triplett

Signature: *Tracy Triplett*

Date & Phone#: (503) 793-3685 7-9-24

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) **Total N's** 1