

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.5				Y
2	7.7				Y
3	7.6				Y
4	7.6				Y
5	7.6	24.1			Y
6	7.6				Y
7	7.6				Y
8	7.6				Y
9	7.6				Y
10	7.4				N
11	7.9				Y
12	7.9	23.6			Y
13	7.7				Y
14	7.6				Y
15	7.5				Y
16	7.9				Y
17	7.9				Y
18	7.8				Y
19	7.9				Y
20	7.7				Y
21	7.6				Y
22	7.6				Y
23	7.9	21.0			Y
24	7.8				Y
25	7.7				Y
26	7.8				Y
27	7.9				Y
28	7.7				Y
29	7.6				Y
30	7.6	18.6			Y
31	7.8				Y

<<Have
minimums
been met for
this day?

County: Clackamas Agency: REGION 1

ENTRY POINT

EP-A

PWS ID 4100187

**CLACKAMAS RIVER WATER -
CLACKAMAS**

Sample period: December 2024
Month/Year

← **Number of excursions during this month:** 1


*(Over 9 excursions in 6 months is a violation.
Entry Point and Distribution excursions are
cumulative). An 'excursion' is any day in which the
water quality parameter(s) fall below the minimum
set by the State.*

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH 7.5
Alk 16.5 (Alkalinity)

Print Name: Tracy Triplett

Signature: 

Date & Phone#: 01-06-2025 (503) 793-3685

Send to DWP within 10 days after end of
sampling period

(No = N = Excursion) **Total N's** 1

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>