

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.9				Y
2	7.8				Y
3	7.7	19.9			Y
4	7.7				Y
5	7.7				Y
6	7.8				Y
7	7.5				Y
8	7.6				Y
9	7.7				Y
10	7.7	21.4			Y
11	7.8				Y
12	7.6				Y
13	7.5				Y
14	7.9				Y
15	7.7				Y
16	8.0				Y
17	8.0	21.7			Y
18	7.6				Y
19	7.7				Y
20	7.7				Y
21	7.7				Y
22	7.7				Y
23	7.9	21.8			Y
24	7.8				Y
25	7.8				Y
26	7.7				Y
27	7.7				Y
28	7.8				Y
29	7.7				Y
30	7.9	22.8			Y
31					

<<Have
minimums
been met for
this day?

County: Clackamas Agency: REGION 1

ENTRY POINT

EP-A

PWS ID 4100187

**CLACKAMAS RIVER WATER -
CLACKAMAS**

Sample period: April 2025
Month/Year

Number of excursions during this month: 0

*(Over 9 excursions in 6 months is a violation.
Entry Point and Distribution excursions are
cumulative). An 'excursion' is any day in which the
water quality parameter(s) fall below the minimum
set by the State.*

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH 7.5
Alk 16.5 (Alkalinity)

Print Name: Tracy Triplett

Signature: Tracy Triplett

Date & Phone#: 05/06/2025 (503)772-9241

Send to DWP within 10 days after end of
sampling period

(No = N = Excursion) **Total N's** 0