

Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Other	Y/N
1	7.9				Y
2	7.9				Y
3	7.9				Y
4	7.6				Y
5	7.6	29.5			Y
6	7.6				Y
7	7.7				Y
8	7.6				Y
9	7.6				Y
10	7.7				Y
11	7.7				Y
12	7.8	30.4			Y
13	7.8	32.5			Y
14	7.7				Y
15	7.6				Y
16	7.6				Y
17	7.6				Y
18	8.0	29.7			Y
19	7.7	29.1			Y
20	7.7	27.8			Y
21	7.7				Y
22	7.7				Y
23	7.8	29.0			Y
24	7.7				Y
25	7.7	27.8			Y
26	7.7	30.1			Y
27	7.7	28.4			Y
28	7.7				Y
29	7.7	29.5			Y
30	7.7	29.0			Y
31					

(No = N = Excursion) **Total N's** 0

<<Have  
minimums  
been met for  
this day?

County: Clackamas Agency: REGION 1

**ENTRY POINT**

**EP-A**

**PWS ID 4100187**

**CLACKAMAS RIVER WATER -  
CLACKAMAS**

**Sample period:** June 2025  
Month/Year

**Number of excursions during this month:** 0

*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.*

Reference

**Minimum Water Quality  
Parameter(s) as set by State:**

pH 7.5  
Alk 16.5 (Alkalinity)

**Print Name:** Tracy Triplett

**Signature:**

**Date & Phone#:** REVISED 07-29-2025 (503)793-3685

Send to DWP within 10 days after end of  
sampling period