

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.9				Y
2	7.9				Y
3	7.9				Y
4	7.6				Y
5	7.6				Y
6	7.6				Y
7	7.7				Y
8	7.6				Y
9	7.6				Y
10	7.7				Y
11	7.7				Y
12	7.8				Y
13	7.8				Y
14	7.7				Y
15	7.6				Y
16	7.6				Y
17	7.6				Y
18	8.0				Y
19	7.7				Y
20	7.7				Y
21	7.7				Y
22	7.7				Y
23	7.8				Y
24	7.7				Y
25	7.7				Y
26	7.7				Y
27	7.7				Y
28	7.7				Y
29	7.7				Y
30	7.7				Y
31					

(No = N = Excursion) **Total N's** 0

<<Have
minimums
been met for
this day?

County: Clackamas Agency: REGION 1

ENTRY POINT

EP-A

PWS ID 4100187

**CLACKAMAS RIVER WATER -
CLACKAMAS**

Sample period: June 2025
Month/Year

Number of excursions during this month: 0


(Over 9 excursions in 6 months is a violation.
Entry Point and Distribution excursions are
cumulative). An 'excursion' is any day in which the
water quality parameter(s) fall below the minimum
set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH 7.5
Alk 16.5 (Alkalinity)

Print Name: Tracy Triplett

Signature: 

Date & Phone#: 07-09-2025 (503)793-3685

Send to DWP within 10 days after end of
sampling period