

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.6	30.6			Y
2	7.6	29.4			Y
3	7.6	29.3			Y
4	7.7				Y
5	7.7				Y
6	7.7				Y
7	7.8	31.7			Y
8	7.8	34.8			Y
9	7.7	31.6			Y
10	7.7				Y
11	7.5	29.6			Y
12	7.8				Y
13	7.9	30.2			Y
14	7.9				Y
15	7.7	32.0			Y
16	7.6	30.8			Y
17	7.7	32.5			Y
18	7.6	30.0			Y
19	7.7	28.5			Y
20	7.6	29.5			Y
21	7.8	30.3			Y
22	7.8	31.0			Y
23	7.7	31.2			Y
24	7.7	29.5			Y
25	7.7	29.9			Y
26	7.7	30.2			Y
27	7.7	30.0			Y
28	7.8	27.7			Y
29	7.6	31.7			Y
30	7.7	31.6			Y
31	7.7	32.6			Y

(No = N = Excursion) **Total N's** 0

<<Have
minimums
been met for
this day?

County: Clackamas Agency: REGION 1

ENTRY POINT

EP-A

PWS ID 4100187

**CLACKAMAS RIVER WATER -
CLACKAMAS**

Sample period: July 2025
Month/Year

Number of excursions during this month: 0

*(Over 9 excursions in 6 months is a violation.
Entry Point and Distribution excursions are
cumulative). An 'excursion' is any day in which the
water quality parameter(s) fall below the minimum
set by the State.*

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH 7.5
Alk 16.5 (Alkalinity)

Print Name: Tracy Triplett

Signature: 

Date & Phone#: 08/01/2025 (503) 793-3685

Send to DWP within 10 days after end of
sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>