

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.7	31.1			Y
2	7.7	31.6			Y
3	7.7	32.1			Y
4	7.9	31.5			Y
5	7.8	30			Y
6	7.7	30.8			Y
7	7.6	31.2			Y
8	7.7	31.9			Y
9	7.7	30.5			Y
10	7.9				Y
11	7.9	32.3			Y
12	7.7	32.1			Y
13	7.7				Y
14	7.7	29.7			Y
15	7.7	33.5			Y
16	7.6	33.2			Y
17	7.7	36.0			Y
18	7.6	35.0			Y
19	7.7	33.0			Y
20	7.8	32.1			Y
21	7.7	32.8			Y
22	7.7	33.6			Y
23	7.7	32.2			Y
24	7.7	30.0			Y
25	7.8	30.4			Y
26	7.8	29.1			Y
27	7.7	29.6			Y
28	7.7	31.9			Y
29	7.7	30.8			Y
30	7.7	28.1			Y
31	7.6	25.4			Y

(No = N = Excursion) **Total N's** 0

<<Have
minimums
been met for
this day?

County: Clackamas Agency: REGION 1

ENTRY POINT

EP-A

PWS ID 4100187

**CLACKAMAS RIVER WATER -
CLACKAMAS**

Sample period: August 2025
Month/Year

Number of excursions during this month: 0

*(Over 9 excursions in 6 months is a violation.
Entry Point and Distribution excursions are
cumulative). An 'excursion' is any day in which the
water quality parameter(s) fall below the minimum
set by the State.*

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH 7.5
Alk 16.5 (Alkalinity) 

Print Name: Tracy Triplett

Signature: 

Date & Phone#: 09/02/2025 (503) 793-3685

Send to DWP within 10 days after end of
sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>