

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.6	32.8			Y
2	7.7	29.3			Y
3	7.7	31.2			Y
4	7.7	32.9			Y
5	7.6	32.7			Y
6	7.6	32.4			Y
7	7.7	26.4			Y
8	7.6	30.1			Y
9	7.8	30.6			Y
10	7.7	31.9			Y
11	7.8	34.9			Y
12	7.7	32.7			Y
13	7.6	29.7			Y
14	7.6	28.4			Y
15	7.6				Y
16	7.6	32.8			Y
17	7.7	29.9			Y
18	7.6	30.5			Y
19	7.6	31.4			Y
20	7.7	28.8			Y
21	7.6	28.5			Y
22	7.6	31.3			Y
23	7.6	31.6			Y
24	7.6	32.7			Y
25	7.6	34.0			Y
26	7.6	30.3			Y
27	7.6	27.4			Y
28	7.6	28.2			Y
29	7.6	32.3			Y
30	7.7	29.2			Y
31					

<<Have
minimums
been met for
this day?

County: Clackamas Agency: REGION 1

ENTRY POINT

EP-A

PWS ID 4100187

**CLACKAMAS RIVER WATER -
CLACKAMAS**

Sample period: September 2025
Month/Year

Number of excursions during this month: 0

*(Over 9 excursions in 6 months is a violation.
Entry Point and Distribution excursions are
cumulative). An 'excursion' is any day in which the
water quality parameter(s) fall below the minimum
set by the State.*

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH 7.5

Alk 16 (Alkalinity)

Print Name: Tracy Triplett

Signature:

Date & Phone#: 10/9/25 (503) 793-3685

Send to DWP within 10 days after end of
sampling period

(No = N = Excursion) **Total N's** 0