

Day	pH	Alk	Phos	Other	Y/N
1	7.6	29.4			Y
2	7.6	34.9			Y
3	7.6	30.7			Y
4	7.6	30.0			Y
5	7.6	30.4			Y
6	7.6				Y
7	7.6	32.3			Y
8	7.5	32.0			Y
9	7.5	31.3			Y
10	7.6	31.5			Y
11	7.5	30.8			Y
12	7.6	31.0			Y
13	7.6	33.0			Y
14	7.5				Y
15	7.6	31.6			Y
16	7.5	30.0			Y
17	7.6	30.4			Y
18	7.5	31.5			Y
19	7.5	31.8			Y
20	7.5	30.9			Y
21	7.5	31.1			Y
22	7.5	32.1			Y
23	7.5	30.1			Y
24	7.5	33.2			Y
25	7.6	32.9			Y
26	7.6	32.0			Y
27	7.6	31.6			Y
28	7.5	31.1			Y
29	7.7	30.1			Y
30	7.5	27.2			Y
31	7.4	29.0			N

<<Have
minimums
been met for
this day?

County: Clackamas Agency: REGION 1

ENTRY POINT

EP-A

PWS ID 4100187

**CLACKAMAS RIVER WATER -
CLACKAMAS**

Sample period: October 2025
Month/Year

Number of excursions during this month: 1

*(Over 9 excursions in 6 months is a violation.
Entry Point and Distribution excursions are
cumulative). An 'excursion' is any day in which the
water quality parameter(s) fall below the minimum
set by the State.*

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH 7.5
Alk 16.5 (Alkalinity)

Print Name: Tracy Triplett

Signature:

Date & Phone#: 11/4/25 (503)793-3665

Send to DWP within 10 days after end of
sampling period

(No = N = Excursion) **Total N's** 1