

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.5	29.6			Y
2	7.5	28.7			Y
3	7.5	27.6			Y
4	7.6	27.5			Y
5	7.6	24.3			Y
6	7.7	25.9			Y
7	7.6	23.0			Y
8	7.7	27.2			Y
9	7.8	24.0			Y
10	7.8	25.8			Y
11	7.8	26.1			Y
12	7.8	25.9			Y
13	7.8	28.0			Y
14	7.8	25.2			Y
15	7.7	26.4			Y
16	7.7	29.8			Y
17	7.8	29.5			Y
18	7.8	29.9			Y
19	7.8				Y
20	7.8	30.9			Y
21	7.8				Y
22	7.7	30.5			Y
23	7.7	30.5			Y
24	7.9	30.7			Y
25	7.8	26.2			Y
26	7.7	30.0			Y
27	7.7				Y
28	7.7	27.2			Y
29	7.6	26.7			Y
30	7.6	24.4			Y
31					

<<Have
minimums
been met for
this day?

County: Clackamas Agency: REGION 1

ENTRY POINT

EP-A

PWS ID 4100187

**CLACKAMAS RIVER WATER -
CLACKAMAS**

Sample period: November 2025
Month/Year

Number of excursions during this month: 0

*(Over 9 excursions in 6 months is a violation.
Entry Point and Distribution excursions are
cumulative). An 'excursion' is any day in which the
water quality parameter(s) fall below the minimum
set by the State.*

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH 7.5

Alk 16.5 (Alkalinity)

Print Name: Tracy Triplett

Signature:

Date & Phone#: 12/01/2025 (503) 793-3685

Send to DWP within 10 days after end of
sampling period

(No = N = Excursion) **Total N's** 0