

Day	pH	Alk	Phos	Other	Y/N
1	7.6	25.9			Y
2	7.6	26.5			Y
3	7.7	26.8			Y
4	7.7	27.0			Y
5	7.7	24.7			Y
6	7.7	24.7			Y
7	7.7	20.5			Y
8	7.8				Y
9	7.8	21.0			Y
10	7.8	22.1			Y
11	7.8	22.8			Y
12	7.6	19.9			Y
13	7.6	19.8			Y
14	7.6	21.2			Y
15	7.7	25.0			Y
16	7.7	24.3			Y
17	7.8	24.4			Y
18	7.9	22.2			Y
19	7.7	21.8			Y
20	7.5	19.7			Y
21	7.6	18.8			Y
22	8.0	21.5			Y
23	7.6	20.8			Y
24	7.8	20.6			Y
25	7.8	21.3			Y
26	7.7	22.4			Y
27	7.8	22.9			Y
28	7.6	23.2			Y
29	7.7	22.8			Y
30	7.6	23.8			Y
31	7.7	23.7			Y

<<Have minimums been met for this day?

County: Clackamas Agency: REGION 1

ENTRY POINT

EP-A

PWS ID 4100187

CLACKAMAS RIVER WATER - CLACKAMAS

Sample period: December 2025
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

Minimum Water Quality Parameter(s) as set by State:


pH

7.5

 Alk

16.5

(Alkalinity)

Print Name: Tracy Triplett
Signature: 
Date & Phone#: 01/07/2026 (503) 793-3685

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) **Total N's**

0
