

Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.6	24.1			Y
2	7.9	22.8			Y
3	7.7	23.4			Y
4	7.7	18.1			Y
5	7.7	20.2			Y
6	7.7				Y
7	7.6	20.3			Y
8	7.7	20.7			Y
9	7.5	21.9			Y
10	7.6	21.8			Y
11	7.6	21.6			Y
12	7.6	23.5			Y
13	7.7	20.6			Y
14	7.7				Y
15	7.7	23.6			Y
16	7.7	24.5			Y
17	7.8	24.8			Y
18	7.8	23.6			Y
19	7.8	23.8			Y
20	7.7	22.9			Y
21	7.7	23.4			Y
22	7.7	24.5			Y
23	7.7	22.9			Y
24	7.7	24.6			Y
25	7.7	24.3			Y
26	7.7	25.3			Y
27	7.7	26.4			Y
28	7.7	25.3			Y
29	7.7	25.0			Y
30	7.6	24.8			Y
31	7.7	25.2			Y

<<Have minimums been met for this day?

County: Clackamas Agency: REGION 1

ENTRY POINT

EP-A

PWS ID 4100187

CLACKAMAS RIVER WATER -
CLACKAMAS

Sample period: January 2026
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH 7.5
Alk 16.5 (Alkalinity)

Print Name: Tracy Triplett

Signature: 

Date & Phone#: 02/02/2026 (503)793-3685

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) **Total N's** 0