

Lead & Copper Rule Corrosion Control

ID #	Sample Location	pH	pH	Alk	Alk	Y/N
1	90 <sup>th</sup> Ave Pump Station	7.6	7.3	20.5	19.1	N
2	5910 SE Hazel Pl	8.1	8.3	22.1	20.9	Y
3	7509 SE Harmony Rd	7.7	7.7	20.9	19.6	Y
4	5804 SE Kellogg Creek Rd	7.7	7.7	20.5	19.7	Y
5	14500 SE Vista Ln.	8.0	8.1	21.6	20.4	Y
6	8480 SE Hood St.	7.5	7.6	19.5	18.8	Y
7	12250 SE Capps Rd.	7.5	7.7	19.3	19.5	Y
8	18262 S Arnett Dr.	8.5	8.8	23.5	22.0	Y
9	17308 S Potter Rd	7.5	7.6	20.6	19.3	Y
10	15937 S. Country Air Rd	7.8	7.7	21.5	19.7	Y
11	Mather Res.			18.2		Y
12	90 <sup>th</sup> Ave Pump St.			19.0		Y
13	7242 SE Lamphier			20.4		Y
14	8606 SE 55 <sup>th</sup> Ave			19.5		Y
15	5910 SE Hazel Pl			19.6		Y
16	6710 SE Catalina Ln			19.4		Y
17	7509 SE Harmony Dr			19.6		Y
18	13270 SE Pheasant Ct			17.0		Y
19	14450 SE Topaz Ave			19.0		Y
20	8480 SE Hood St			18.6		Y
21	16520 SE Dagmar			19.5		Y
22	7776 SE Jennings			18.5		Y
23	12250 SE Capps Rd			18.9		Y
24	17308 S. Potter Rd			19.8		Y
25	18967 S. Grasse Rd			21.6		Y
26	18858 S. Dillman Rd			20.5		Y

(N = No = Excursion) Total N's 1

<Has sample met the minimum(s)?

County: Clackamas

Agency: REGION 1

**DISTRIBUTION**

PWS ID 4100187

CLACKAMAS RIVER WATER - CLACKAMAS

Sample Period: January 2022  
Month/Year

Sample Frequency: Every 6 months

Distribution Samples required: 7

Number of excursions during this Sample Period = 1

(Number of locations when any WQP was less than the minimum.)

Note: Entry Point and Distribution Excursions are cumulative. Add Entry Point and Distribution Excursions to get total for sample period.

Reference

Minimum Water Quality Parameters as set by State:

pH 7.5

Print Name: Tracy Triplett  
Signature: Tracy Triplett  
Date: 2-15-22

Send to Drinking Water Program within 10 days after end of sampling period:

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350  
Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>

1-10-22