Oregon Health Authority

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

ID #	Sample Location	pH	Alk	PO4	Other	Y/N
1	90th Ave Pump Station	7.3	18.3			N
2	5910 SE Hazel Pl	7.9	20.2			Y
3	7509 SE Harmony	7.5	18.0			Y
4	5804 SE Kellogg Cr. Rd	8.1	19.5			Y
5	14500 SE Vista Ln.	7.9	20.9			Y
6	8480 SE Hood St.	7.5	18.2			Y
7	12250 SE Capps Rd	7.6	17.9			Y
8	18262 S. Arnett Dr.	8.8	21.8			Y
9	17308 S. Potter Rd.	7.8	19.2			Y
10	15937 S. Country Air Ct	8.0	20.0			Y

(N = No = Excursion) **Total N's** 1

<Has sample met the minimum(s)?

County: Clackamas

Agency: REGION 1

DISTRIBUTION

PWS ID 4100187

CLACKAMAS RIVER WATER - CLACKAMAS

Sample Period: June 2022 *Month/Year*

Sample Frequency: Every 6 months

Distribution Samples required: 7

Number of excursions during this Sample Period = 1

(Number of locations when any WQP was less than the minimum.)

Note: Entry Point and Distribution Excursions are cumulative. Add Entry Point and Distribution Excursions to get total for sample period.

Reference

Minimum Water Quality Parameters as set by State:

pH 7.5

Print Name: Tracy Triplett

Signature: Tracy Triplett

Date: July 07, 2022

Send to Drinking Water Program within 10 days after end of sampling period:

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: http://healthoregon.org/dwp/